

Corrigendum - 1

21.09.2015

With reference to NIT No.: 33 / HVAC/RYA/ EEC-IV/ CE (E) / NRDA / 2015-16, Raipur, Dated: 28.08.2015 for the work of %Supply and installation of HVAC Works for Rajya Yojana Ayog Building at Naya Raipur+, the following corrigendum - 1 is made in the BOQ:-

Sl. No	Bidders Queries	Clarification
1	<p><u>Boq item no. : B.1 (Note)</u></p> <p>a-The position of indoor and outer split A/C unit will be decided by Engineer in Charge.</p> <p>b-All necessary accessories (cable ,pin tap etc)for electrical connection will be supplied and installed by supplier.</p> <p>c-The electrical connection from supply point to A/C unit shall be provided by supplier.</p> <p>D-Drainage outlet pipe shall be installed including drilling of wall of required diameter. The hole should slope downward toward the exterior to ensure adequate drainage.</p> <p>e- The drainage pipe allows water to drain in an appropriate place.</p> <p>f-All necessary civil work (hole etc) will done by supplier, including the fixture good as approved by Engineer in charge.</p> <p>g-The indoor and outdoor unit shall be fixing in place with the standard power coated MS frame and support /brackets etc including all fixtures as required as per site .</p>	<p>This is the general instruction for installation of indoor and outer split A/C unit.</p>
2	Star rating for Split AC	5 Star rating
3	The distance between B/W indoors and out door unit	It is clarified that, the distance between B/W indoors and out door unit shall be upto 4 metre of copper piping with insulation and drainage pipe upto 5.0 metre length
4	As per NIT Clause No. 4-Pre qualification Criteria, no criteria towards similar work experience has been mentioned. Kindly arrange to inform the minimum amount of order and no. Of orders of similar work completed before tendering date.	Please refer para 4.1 & 4.2 of Detailed NIT
5	The makes provided for electrical panel have very high delivery period, since the above work has only one panel and are being existing contractors of NRDA, can the makes of panels installed in other sites be supplied.	Please refer Make list

The above modifications shall form part of the agreement. The rates quoted by bidder in above items shall be after considering the clarifications made in this corrigendum.

The Last date of submission and opening of tender is extended from 23.09.2015 to 28.09.2015.

The decision of CEO, NRDA shall be final and binding in the matter.

All other terms and conditions shall remain same.