



NAYA RAIPUR DEVELOPMENT AUTHORITY

Utility block, Capitol Complex, Sector- 19, Naya Raipur- 492 002, Chhattisgarh
Tel No: + 91 771 2511500; Fax No.: +91 771 2511400., Website: www.navaraipur.com

Corrigendum -1

Date: 05/10/2016

Name of the Work: “Supply, Installation, Testing and Commissioning of HT/LT Distribution system for Retail Complex building at sector-21 of Naya Raipur”

With reference to NIT No. 104 /HT-LT-DS/RB/ELECT/CE(E)/NRDA/2016-17, Naya Raipur
Dated: 21.09.2016; The following Corrigendum-1 is made.

Sr. No.	Description	In place of	Read As
01	Last Date and time of submission of Tender	14-10-2016 15.00Hrs	& 21-10-2016 & 15.00Hrs
02	Date and time of opening of Tender	14-10-2016 16.00Hrs	& 21-10-2016 & 16.00Hrs

Clarifications based on Pre bid queries received is provided in Annexure 1. The same shall form part of agreement .All other terms and condition shall remain same.

नया रायपुर – मेरा रायपुर

Chief Executive Officer

ANNEXURE A

Reply to Pre Bid Queries

Supply, Installation, Testing and Commissioning of HT/LT Distribution system for Retail Complex building at sector-21 of Naya Raipur

NIT No. 104 /HT-LT-DS/RB/ELECT/CE(E)/NRDA/2016-17, Naya Raipur

Dated: 21.09.2016

Sl.	No. Title/Item No.	Description	Bidders Queries	Clarification/New Items
1	<u>Bill of quantity</u>	Cable sub head		
a	(Bill of quantity) item no. 4.1.2 1cx500 sq mm.-	Supplying and laying following sizes one number FRLS PVC insulated/ XLPE, PVC sheathed, steel armoured, aluminium conductor power cable of 1.1 KV grade direct in ground including excavation, sand cushioning, protective covering and refilling the trench etc as required	These two item no. have the same quantity of cable but for one item the length is in negative in 4.1.2 the cable seems to be grounded while that of 4.3.9 seems to be in open air this means this two have different application .Kindly confirm wheather one item qty is positive and for the other one is negative is correct or not	no change quantity is ok
b	(Bill of quantity) item no. 4.3.9 1cx500 sq mm.	Supplying and laying following sizes one number FRLS PVC insulated/ XLPE, PVC sheathed, steel armoured, aluminium conductor power cable of 1.1 KV grade on surface/ existing cable tray with 25x3 mm M.S flat clamp and steel dash fastener/ G.I. bolts and nuts as required.		Read as 3826 rmt in place of (- 10674) rmt
C	(Bill of quantity) item no. 1.1.1	3x300Sq.mm. 33 KV XLPE cable Steel Armoured Aluminium Conductor	Please confirm whether you required Flat Steel or Round Armoured Aluminium Conductor cable.	It shall be round wire.
2	(BOQ) Bill of quantity	LT Panel	we request you to please approve system house Manufacture of LT Panel of the approved makes	System house approved by company
3	Tender Document	Payment terms	kindnly specify the payment terms specified for this tender as the same is not present in the tender document	Payment condition are as follows 1. Upon receipt of material at site store - 65% 2. Upon installation of equipment - 15 % 3. Upon commissioning of equipment - 10 % 4. After successful trial and run period-10 %
4	BOQ / Technical specification	Energy Meter	Kindly provide us the approved make list of En ergy meter	Secure ,L & T ,L & G and as approved make of CSPDCL
5	BOQ / Technical specification /SLD	33 KV HT Panel	The IP Protection of the HT Panel Stated in the SLD is IP 65 where as the IP PROTECTION OF ht Panel is generally IP4X as per the manufacturer standered . We have discussed to the approved vendor and they manufacture IP 4X as per there manufacturer standered . Kindly consider IP 4X Protection for 33 KV HT Panel	The IP Protectin shall be IP 4X.
6	Technical specification	colour of 33 KV HT Panel and LT Panel	we request you to please consider colour of the HT Panel & LT Panel as per manufacturer standered	GREY Colour as per IS standard
7	Technical specification & SLD	33 KV HT Panel	The breaking capacity of the breaker stated in the BOQ is 26 KA while in SLD IT IS 25KA. Kindly confirm what to consider 25 KA or 26 KA	It shall be 26 KA.
8	BOQ /SLD	HT Panel /LT Panel	Therer is a diference in BOQ and SLD .The switchgear stated in the BOQ differ from the SLD .Kindly confirm what we have to refer	Modified SLD has been uploaded.
a	(Bill of quantity) Item no. 2.13	VTPNDB-L&P-EM-E9A (Same as E9B, E10A & E10B) Incomer: 63A, 4P, 415V, MCB, 10kA -1 No.		Read as 16 KA in palce of 10 KA
b	(Bill of quantity) item no. 2.14	MDB-E4-L0 Incomer: 800A, 4P, 415V, MCCB, 36kA - 1 No.		Read as 630 A in palce of 800 A

Sl.	No. Title/Item No.	Description	Bidders Queries	Clarification/New Items
C	(Bill of quantity) Item no. 2.17.13	VENTILATION PANEL-E9A-L0, (Same for E9B, E10A, E10B) BASEMENT Outgoings 32A, 4P, 415V, MCB, 10kA -2 No.		Read as 63 A in palce of 32 A & Read as 16 KA in palce of 10 KA
9	BOQ /Technical specification of LT Panel	LT Panel	In the BOQ it is stated the Power distribution /control type tested panel conforming to IS : 61439 .Kindly confirm only Main LT panel are totally type test or all panel like SDB ,Capacitor panel and feeder pillars should also be TTA.Please accept PTTA Type panel Except MDBs	LT Panels MDBs should be totally type test panels and other SDBs ,capacitor panel etc shall be PTTA
10	Approved Make list	LT Panel as per your approved list Schneider/L&T/ABB/CG/C&S	The delivery of above manufacturer is 12-18 weeks after approval of drawing. Now, we kindly requested you to give approval for CPRI approved Vendor with ISO certificates like Peaton Electricity Company Limited, SPC & BSPCL.	Not agreed
11	Approved Make list	All Distribution Boards.	List of approved make of Distribution Board is not incorporate. Please confirm, can we supply the Distribution board with same make of MCB/RCB.	Refer the Approved Make list Item no.14
12	Approved Make list	Compact Sandwich type Copper Bus Trunking.	In the list of approved make, Copper Bus Duct has only 3 makes i.e, L&T/Schneider/Legarand. C&S is a reputed Brand for Bus Ducts and is approved in all major departments like CPWD, AAI, ISRO, BHEL etc. We request you to consider C&S, So that the tender can be more competititive.	Not agreed
13	Technical specification	All LT Cables you required FRLS PVC insulated/XLPE PVC sheathed steel armoured power conductor cable of 1.1KV>	Please confirm all the LT cables Flat steel armoured or Round wire armoured.	it shall be flat steel armoured
14	Technical specification	Cable Tray & Accessories	Please specify Cable Tray you required perforated type or Ladder type.	it shall be perforated type
15	Detailed NIT	Detailed NIT S.No.20, Performance Bank Gurantee of requisite amount.	Please provide the % of Performance Gurantee required.	Performance Gurantee is 5 % .Plz Refer the SCHEDULE- E
16	EMD		As per MSME Act & Gazette Notification from Ministry of MSME dated 23.02.2012, it has been made mandatory to give EMD Exemption to MSME Registered Contractors. The followign department given Exemption for EMD: AAI, CCIL, Port Trust, ISRO, HAL, ECIL & IOCL. We are enclosing herewith the copy of NIT for your reference.	Not agreed
17	Extension of Tendor		We request you to kindly extend submission period for 10 days after getting of all the clarifiations which enable us to quote competitively.	Ref corrigendum-1
18	Note :- Condition			The minimum quoted rate will be considered for same description of items