

Corrigendum - 1

17.09.2015

With reference to NIT No.: 31/Ry-F/ EEC-IV/ CE (E) / NRDA / 2015-16, Raipur, Dated: 28.08.2015 for the work of providing and installation of Modular office Furniture for Rajya Yojana Ayog Office Building at Sector 19 of Naya Raipur, the following corrigendum - 1 is made in the BOQ:-

Sl. No	Bidders Queries	Clarification
1	Item No. 1 (b) of BOQ, Schedule A; The thickness of Prelaminated particle board work surface is not mentioned.	It is clarified that, the thickness of Prelaminated particle board work surface is 25mm for the item no. 1(b) of BOQ, Schedule A
2	Item No. 5 of BOQ, Schedule A; The size of the tables in the description of work has not been given for Office Hall Table.	It is clarified that, the size of Office Hall Table in Item No. 5 of BOQs, Schedule A is 1500mmx750mmx750mm and side unit is 900mmx450mmx750mm.
3	Item No. 6 of BOQ, Schedule A; The size of the tables in the description of work has not been given for PA / Staff & Advisor Table / Record Room & Programmer.	It is clarified that, the size of PA / Staff & Advisor Table / Record Room & Programmer in Item No. 6 of BOQs, Schedule A is 1500mmx750mmx750mm and side unit is 900mmx450mmx750mm.
4	Please clarify whether exterior or interior board is to be used in post forming.	All board should be Exterior Grade bonded with phenol formaldehyde.
5	Please Clarify the EMD Amount	The EMD Amount is mentioned in Detailed NIT of Tender Document.
6	In your Pre Qualification Bid Sl. No. 4.2 (A) . (B) you have asked for BIFMA. Please clarify, you required only BIFMA Membership (which anybody can get) or ANSI /BIFMA Complied Products (M7.1 / x5.1) with in house BIFMA testing lab	Only Current BIFMA Certificate shall be considered for Eligibility.
7	In many of the products, in the Tender List, is been asked with chrome finish. You would know that Chrome is considered hazardous, due to acute (corrosive) and chronic (carcinogenic) health hazard, and fire (oxidizer) hazard. As we know that NRDA campus is designed keeping Green Building norms and concepts. We request you to change the Finish to Powder coating, Stainless steel or Aluminum in place of Chrome.	It is clarified that, in the description of items for item no. 20,21,22 and 23 of BOQ, Schedule A, chrome finish for various items shall be replaced with Powder Coating.

The above modifications shall form part of the agreement. The rates quoted by bidder in above items shall be after considering the clarifications made in this corrigendum.

The decision of CEO, NRDA shall be final and binding in the matter.

All other terms and conditions shall remain same.