



Credible Chhattisgarh
विश्वसनीय छत्तीसगढ़

NAYA RAIPUR DEVELOPMENT AUTHORITY
BESIDE MAHANADI DWAR OF MANTRALAYA
RAIPUR (CHHATTISGARH) 492001

PH.NO.0771-4066011, FAX 0771-4066188, e-mail. ceo@nayaipur.com

CORRIGENDUM-II

No.: 1232/4(3)/CEE-EEC2/HOD/NRDA/2012-13 Raipur, dated 01/09/2012

Following corrigendum in NIT No: 1079/HOD/Mod-2/CEE/EEC-2/NRDA/2012-2013, Raipur, dated: 03.08.12 for Designing, manufacturing, supplying, assembling, testing and commissioning of modular workstation (Modular office Furniture) MOD-2 for HOD at Capitol Complex, Naya Raipur.
is issued -

1- Reply to additional pre-bid queries is attached at Annexure –I
herewith. This shall also form part of the tender document, in
addition to the modified tender document issued along with
Corrigendum II


2 - All other conditions shall remain unchanged.

sd/
Chief Executive Officer
Naya Raipur Development authority
Raipur

ANNEXURE-I Reply of additional pre bid queries

S.No.	Details of Query	Reply of NRDA
1	(a)Item B (of BOQ) – Modular Storage Unit – Kindly confirm the size of Storage Unit in terms of Height and Depth of Unit. (b)Also please confirm whether the Top of Unit would be prelaminated or metal and the shutter should be sliding or openable.	(a) Height- 1200mm Depth- 450mm (b) Top unit shall be Metal Top & openable shutter
2	Item B.1 (of BOQ) – Over head Storage – There are two type of metal thicknesses 1.2mm and 1mm MS sheet. Pls confirm what should be thickness of metal for body.	1.2mm thick M.S. sheet shall be used.
3	Item A.2.5 HOD Meeting Table (of BOQ)- As per technical specifications the Top should be postformed, however as per drawing there is curve at edges hence postforming would not be possible. Also drawing states laminated Top 25mm thk. Pls confirm.	Shall be as per drawing on post farming shall not be possible.
4	Item A.2.1 & A.2.2 (of BOQ) – The depth of drawer defined is 900mm however since the Table is of 750mm Depth Hence the drawer should be of same depth only. As per technical specifications the modesty should be 35-38mm thk, please clarify the same.	Depth of drawer shall 750 mm. The modesty shall as per technical specification.
5	List & number of mock ups to be produced for evaluation.	In modification of earlier provision, Mock up of Following items shall be submitted . 1-Loose Table Types— Steno Table HOD Table with Side & Back HOD Meeting Table (one segment) 2-Modular storage Cabinet - 750x450x1200 3- Centre Table 4-CPU trolley 1 sample

sd/
Chief Executive Officer
Naya Raipur Development authority
Raipur



--	--	--	--

